



NOTES:

1. HYDRANT CONNECTOR MAY BE USED IN LIEU OF ANCHOR COUPLING.
2. HYDRANT DEPTH OF BURY SHALL MATCH MFGR.'S BURY LINE.
3. HYDRANTS SHALL BE LOCATED:
 - ONE FOOT BEHIND SIDEWALK, OR
 - IF NO SIDEWALK, 6 FEET BEHIND CURB, OR
 - IF NO SIDEWALK OR CURB, ONE FOOT INSIDE OF R/W.
4. WHERE ANCHOR COUPLING IS 4 FEET LONG, PROVIDE DIP W/RET. GLD. OR TWO 3/4" RODS.

THIS DETAIL WAS TAKEN FROM THE CITY OF ATLANTA'S WEBSITE. IT MAY HAVE BEEN MODIFIED AND SHOULD BE REVIEWED THOROUGHLY.

City of Atlanta



STANDARD DETAILS

TYPICAL FIRE HYDRANT

REV.

DATE: OCT. 2011

ORIG. DATE: OCT. 2004

SCALE: N.T.S.

DETAIL NO. WR-G_FH001