



DIMENSIONS IN INCHES FOR PIPE HANGERS			
PIPE SIZE	A	B	C (RADIUS)
8"	6.53	2.00	4.53
12"	8.60	2.00	6.60
16"	10.70	2.00	8.70

**NOTES:**

1. PRIMER SHALL BE NO. 1-B ORANGE PRIMER AND CONFORM TO GEORGIA D.O.T. ARTICLE 870.02 PRIMER SHALL BE APPLIED TO A MINIMUM THICKNESS OF 4 MILS.
2. PAINT SHALL BE NO.3-A GREEN, BRUSHING, ROLLER AIRLESS TYPE AND CONFORM TO GEORGIA D.O.T. ARTICLE 870.02 PAINT SHALL BE APPLIED TO A MINIMUM THICKNESS OF 10 MILS.
3. TWO BOTTOM ASSEMBLIES USED TOGETHER MAYBE REQUIRED IN SOME INSTALLATIONS.

THIS DETAIL WAS TAKEN FROM THE CITY OF ATLANTA'S WEBSITE. IT MAY HAVE BEEN MODIFIED AND SHOULD BE REVIEWED THOROUGHLY.

City of Atlanta



**STANDARD DETAILS**

**PIPE HANGER**

REV.

DATE: OCT. 2011

ORIG. DATE: OCT. 2004

SCALE: N.T.S.

DETAIL NO. WR-G\_AN005